

Date of Study: 02May2023

01May2023 / Basic Condition / 26.9 MAF / Balanced  
Min Serv 1st Half / Full Serv -3.1 kcfs 2nd Half / Nav End Date: Dec 01  
Elevations & Storages are for Date Shown  
Avg Discharge & Energy are Monthly Values

	2023										2024	
	30Apr	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	29Feb	
<b>Fort Peck</b>												
Elev NGVD29	2221.9	2224.0	2227.9	2228.8	2228.3	2228.0	2228.3	2228.5	2228.0	2227.3	2227.0	
Disch kcfs	5.0	6.9	9.0	9.0	9.0	6.8	4.5	4.5	7.5	8.5	8.5	
<b>Garrison</b>												
Elev NGVD29	1829.2	1830.5	1835.8	1838.6	1837.9	1837.0	1836.7	1835.9	1834.8	1833.0	1831.7	
Disch kcfs	16.6	19.5	22.0	22.0	22.0	18.5	15.0	15.0	17.2	22.0	22.0	
<b>Oahe</b>												
Elev NGVD29	1599.8	1602.1	1603.4	1602.2	1600.3	1598.5	1597.7	1597.7	1598.5	1599.8	1601.5	
Disch kcfs	9.1	14.2	22.9	30.2	30.5	27.2	18.0	14.7	12.6	15.9	15.4	
<b>Big Bend</b>												
Elev NGVD29	1420.9	1420.6	1420.4	1420.8	1420.5	1420.7	1420.7	1420.5	1421.0	1420.7	1420.5	
Disch kcfs	10.3	14.3	23.0	29.4	30.4	26.7	17.7	14.8	12.1	16.1	15.5	
<b>Fort Randall</b>												
Elev NGVD29	1355.2	1355.1	1355.4	1354.9	1355.2	1353.6	1344.6	1337.4	1338.9	1344.6	1350.2	
Disch kcfs	13.1	17.8	25.7	30.2	29.9	29.1	28.2	21.9	11.1	10.8	9.5	
<b>Gavins Point</b>												
Elev NGVD29	1206.1	1206.0	1206.1	1206.0	1206.5	1207.5	1207.4	1207.5	1207.5	1207.5	1205.9	
Disch kcfs	16.5	20.5	28.0	31.3	31.0	30.5	30.1	24.6	12.5	12.5	12.5	
<b>System</b>												
Storage KAF	49595	50964	53648	54317	53466	52534	51617	50988	50850	50924	51311	
Energy GWh	6696	578	769	916	917	792	650	531	470	560	514	
Ave Cap MW		2374	2387	2400	2395	2386	2373	2338	2330	2340	2361	

01May2023 / Lower Basic Condition / 20.7 MAF / Balanced  
Min Serv 1st Half / Full Serv -5.5 kcfs 2nd Half / Nav End Date: Nov 28

	2023										2024	
	30Apr	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	29Feb	
<b>Fort Peck</b>												
Elev NGVD29	2221.9	2222.8	2224.2	2223.8	2222.6	2221.8	2221.7	2221.6	2220.7	2220.1	2219.6	
Disch kcfs	5.0	6.9	8.0	8.0	8.0	6.0	4.0	4.0	7.0	7.0	7.0	
<b>Garrison</b>												
Elev NGVD29	1829.2	1829.7	1833.1	1834.8	1833.8	1832.7	1832.0	1830.9	1829.1	1827.3	1825.7	
Disch kcfs	16.6	17.5	19.0	19.0	19.0	16.5	14.0	14.0	17.6	19.0	19.0	
<b>Oahe</b>												
Elev NGVD29	1599.8	1600.3	1599.6	1597.4	1595.0	1592.9	1592.4	1592.9	1593.7	1594.3	1595.2	
Disch kcfs	9.1	17.9	25.9	29.2	28.8	25.4	15.5	11.6	13.2	16.4	16.1	
<b>Big Bend</b>												
Elev NGVD29	1420.9	1420.6	1420.4	1420.9	1420.5	1420.7	1420.7	1420.4	1421.0	1420.7	1420.5	
Disch kcfs	10.3	17.9	26.1	28.5	28.8	24.9	15.2	11.8	12.5	16.7	16.2	
<b>Fort Randall</b>												
Elev NGVD29	1355.2	1355.1	1355.4	1355.0	1355.1	1353.5	1344.1	1337.6	1339.0	1344.7	1350.2	
Disch kcfs	13.1	19.5	27.1	28.7	28.1	27.0	26.2	18.2	11.5	11.2	10.1	
<b>Gavins Point</b>												
Elev NGVD29	1206.1	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.6	1207.5	1207.5	1206.0	
Disch kcfs	16.5	20.5	28.0	28.8	28.5	28.0	27.6	20.3	12.5	12.5	12.5	
<b>System</b>												
Storage KAF	49595	49993	51047	50882	49727	48620	47583	46969	46619	46485	46562	
Energy GWh	6252	612	771	841	831	716	580	444	466	516	475	
Ave Cap MW		2361	2358	2360	2348	2334	2320	2285	2273	2278	2293	

01May2023 / Upper Basic Condition / 34.0 MAF / Balanced  
Min Serv 1st Half / Full Serv 2nd Half / Nav End Date: Dec 10

	2023										2024	
	30Apr	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	29Feb	
<b>Fort Peck</b>												
Elev NGVD29	2221.9	2225.5	2232.2	2234.5	2234.1	2233.9	2234.4	2234.9	2234.6	2234.1	2233.9	
Disch kcfs	5.0	8.1	10.0	10.0	10.0	7.2	4.5	4.5	8.0	9.5	9.5	
<b>Garrison</b>												
Elev NGVD29	1829.2	1832.5	1840.5	1844.7	1843.8	1842.6	1842.0	1840.9	1839.9	1838.4	1837.4	
Disch kcfs	16.6	21.5	27.0	27.0	27.0	23.2	18.5	18.5	18.5	23.5	23.5	
<b>Oahe</b>												
Elev NGVD29	1599.8	1604.0	1608.0	1608.2	1607.3	1606.5	1606.3	1605.5	1605.3	1606.1	1607.4	
Disch kcfs	9.1	10.2	17.5	29.2	31.7	28.4	19.3	22.5	18.2	20.0	18.7	
<b>Big Bend</b>												
Elev NGVD29	1420.9	1420.6	1420.4	1420.8	1420.5	1420.7	1420.7	1420.5	1421.0	1420.7	1420.5	
Disch kcfs	10.3	10.4	17.6	28.4	31.7	27.9	19.0	22.5	17.7	20.2	18.8	
<b>Fort Randall</b>												
Elev NGVD29	1355.2	1355.1	1355.5	1354.9	1355.2	1353.6	1344.6	1338.4	1339.0	1344.7	1350.2	
Disch kcfs	13.1	16.0	21.7	29.7	31.4	30.5	29.5	28.6	17.7	15.2	13.4	
<b>Gavins Point</b>												
Elev NGVD29	1206.1	1206.0	1206.1	1206.1	1206.5	1207.5	1207.5	1207.5	1207.5	1207.4	1206.0	
Disch kcfs	16.5	20.5	25.6	31.5	33.2	32.6	32.0	31.1	20.5	17.5	17.5	
<b>System</b>												
Storage KAF	49595	52361	57331	59269	58624	57796	56988	56123	55734	55714	56121	
Energy GWh	7543	550	738	975	1022	884	725	717	624	686	621	
Ave Cap MW		2390	2430	2452	2451	2448	2438	2401	2384	2396	2418	

Date of Study: 02May2023

01May2023 / Basic Condition / 26.9 MAF / Balanced  
Values in 1000 acre-ft Except as Indicated  
F-Sum: Sum of Forecasted Values. \*: Previous Month's Data

	2023									2024	
	*30Apr	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	29Feb
	F-Sum										
<b>Fort Peck</b>											
Reach Inflow	5860	1060	1600	810	350	310	360	370	330	310	360
Depletion	5	249	309	37	-186	-123	-41	-6	-72	-100	-63
Reg Inflow	5855	811	1290	773	536	433	401	376	402	410	423
Evap	418	3	1	44	81	93	70	69	48	6	4
Release	4484	422	536	553	553	402	277	268	461	523	489
Stor Change	953	385	754	176	-98	-62	54	39	-107	-119	-69
Storage	*12417	12802	13556	13732	13634	13572	13626	13665	13558	13440	13371
Elev NGVD29	*2221.9	2224.0	2227.9	2228.8	2228.3	2228.0	2228.3	2228.5	2228.0	2227.3	2227.0
Disch kcfs	*5.0	6.9	9.0	9.0	9.0	6.8	4.5	4.5	7.5	8.5	8.5
Ave Power MW		80	106	107	107	80	54	54	89	101	100
Ave Cap MW		205	209	212	212	211	212	212	212	211	210
Energy GWh	641.7	59.2	76.0	79.5	79.6	57.7	40.0	38.8	66.3	74.8	69.8
<b>Garrison</b>											
Reach Inflow	8950	1380	2900	1900	610	430	510	370	250	250	350
Depletion	403	221	621	209	-56	-82	-156	-136	-90	-74	-53
Reg Inflow	13000	1555	2807	2244	1219	951	943	774	777	838	892
Evap	497	-2	-29	14	97	123	120	106	71	-2	0
Release	11802	1198	1309	1353	1353	1101	922	893	1055	1353	1265
Stor Change	702	359	1527	878	-230	-273	-99	-224	-350	-513	-373
Storage	*15333	15692	17219	18097	17867	17594	17494	17270	16921	16408	16035
Elev NGVD29	*1829.2	1830.5	1835.8	1838.6	1837.9	1837.0	1836.7	1835.9	1834.8	1833.0	1831.7
Disch kcfs	*16.6	19.5	22.0	22.0	22.0	18.5	15.0	15.0	17.2	22.0	22.0
Ave Power MW		232	266	272	274	230	187	186	212	267	265
Ave Cap MW		534	548	566	570	566	564	562	558	551	544
Energy GWh	1750.7	172.7	191.7	202.6	203.8	165.7	139.1	134.2	157.4	198.9	184.5
<b>Oahe</b>											
Reach Inflow	1460	350	450	200	85	110	75	65	12	13	100
Depletion	109	25	38	50	20	0	-10	-7	-6	-4	2
Reg Inflow	13135	1504	1721	1503	1418	1235	1007	964	1059	1359	1363
Evap	448	-15	-27	14	77	114	103	92	76	8	5
Release	12196	876	1360	1855	1872	1620	1105	875	777	975	884
Stor Change	490	643	389	-366	-532	-498	-201	-2	206	377	475
Storage	*16411	17054	17443	17077	16545	16047	15846	15844	16050	16426	16901
Elev NGVD29	*1599.8	1602.1	1603.4	1602.2	1600.3	1598.5	1597.7	1597.7	1598.5	1599.8	1601.5
Disch kcfs	*9.1	14.2	22.9	30.2	30.5	27.2	18.0	14.7	12.6	15.9	15.4
Ave Power MW		164	265	346	346	306	202	165	143	180	177
Ave Cap MW		676	685	685	677	669	661	658	661	667	675
Energy GWh	1679.8	122.2	190.5	257.7	257.1	220.4	150.2	118.7	106.2	133.9	122.9
<b>Big Bend</b>											
Reg Inflow	12191	870	1358	1853	1872	1622	1108	877	777	973	882
Evap	102	3	3	19	24	21	15	10	5	1	0
Release	12109	881	1367	1810	1869	1590	1088	883	742	991	890
Storage	*1683	1669	1657	1681	1660	1670	1674	1659	1690	1671	1663
Elev NGVD29	*1420.9	1420.6	1420.4	1420.8	1420.5	1420.7	1420.7	1420.5	1421.0	1420.7	1420.5
Disch kcfs	*10.3	14.3	23.0	29.4	30.4	26.7	17.7	14.8	12.1	16.1	15.5
Ave Power MW		59	92	116	120	106	72	61	50	66	63
Ave Cap MW		452	439	431	430	434	447	451	456	449	451
Energy GWh	589.9	43.7	66.4	86.4	89.1	76.4	53.7	43.8	37.1	49.1	44.1
<b>Fort Randall</b>											
Reach Inflow	712	230	210	70	50	40	1	0	15	35	60
Depletion	117	6	24	50	32	12	-2	-2	-2	-1	-1
Reg Inflow	12686	1085	1549	1830	1884	1628	1091	891	768	1014	946
Evap	123	-2	-1	13	27	34	30	14	5	1	1
Release	12978	1097	1527	1856	1837	1729	1734	1305	681	665	547
Stor Change	-415	-10	23	-40	19	-134	-672	-428	82	348	398
Storage	*3430	3420	3443	3403	3422	3289	2616	2188	2269	2617	3015
Elev NGVD29	*1355.2	1355.1	1355.4	1354.9	1355.2	1353.6	1344.6	1337.4	1338.9	1344.6	1350.2
Disch kcfs	*13.1	17.8	25.7	30.2	29.9	29.1	28.2	21.9	11.1	10.8	9.5
Ave Power MW		164	234	274	271	262	245	177	89	90	83
Ave Cap MW		381	381	381	381	379	362	327	316	335	355
Energy GWh	1385.1	122.2	168.5	203.6	201.6	188.8	182.0	127.2	66.1	67.1	58.1
<b>Gavins Point</b>											
Reach Inflow	1340	195	190	140	120	115	120	120	100	100	140
Depletion	160	5	27	66	37	3	3	9	11	1	-1
Reg Inflow	14170	1259	1671	1928	1921	1844	1856	1469	770	768	684
Evap	32	2	1	6	5	6	6	4	2	0	0
Release	14142	1259	1667	1925	1905	1815	1851	1464	769	769	719
Stor Change	-4	-3	2	-2	11	24	-1	1	0	-0	-35
Storage	*330	327	330	327	338	362	361	362	362	362	326
Elev NGVD29	*1206.1	1206.0	1206.1	1206.0	1206.5	1207.5	1207.4	1207.5	1207.5	1207.5	1205.9
Disch kcfs	*16.5	20.5	28.0	31.3	31.0	30.5	30.1	24.6	12.5	12.5	12.5
Ave Power MW		78	105	116	115	115	115	94	49	49	49
Ave Cap MW		125	125	125	125	127	127	127	127	127	126
Energy GWh	648.9	58.3	75.7	86.2	85.5	83.0	85.2	68.0	36.5	36.5	34.1
<b>Sioux City</b>											
Reach Inflow	1990	450	440	330	190	140	110	90	70	60	110
Depletion	273	17	52	128	79	10	-6	-4	-2	-1	-1
Reg Flow	15869	1674	2049	2120	2018	1945	1967	1597	841	830	830
Reg Flow kcfs		27.2	34.4	34.5	32.8	32.7	32.0	26.8	13.7	13.5	14.4
<b>Total</b>											
Reach Inflow	20312	3665	5790	3450	1405	1145	1176	1015	777	768	1120
Depletion	1066	524	1071	539	-74	-180	-211	-146	-161	-180	-117
Evap	1619	-12	-52	110	311	392	344	294	207	15	10
Storage											
Ave Power MW		777	1068	1231	1232	1100	874	737	631	753	738
Ave Cap MW		2374	2387	2400	2395	2386	2373	2338	2330	2340	2361
Energy GWh	6696.0	578.4	768.7	916.0	916.7	792.0	650.1	530.7	469.6	560.3	513.5
Daily GWh		18.7	25.6	29.5	29.6	26.4	21.0	17.7	15.1	18.1	17.7

Date of Study: 02May2023

01May2023 / Lower Basic Condition / 20.7 MAF / Balanced  
Values in 1000 acre-ft Except as Indicated  
F-Sum: Sum of Forecasted Values. \*: Previous Month's Data

	2023									2024	
	*30Apr	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	29Feb
	F-Sum										
<b>Fort Peck</b>											
Reach Inflow	4152	742	1040	526	245	232	288	296	264	248	270
Depletion	201	160	287	80	-100	-66	-3	10	-49	-75	-42
Reg Inflow	3951	582	753	446	345	299	291	286	313	323	312
Evap	391	3	1	42	76	87	65	64	44	6	3
Release	3987	422	476	492	492	357	246	238	430	430	403
Stor Change	-427	156	276	-87	-222	-146	-20	-16	-161	-113	-94
Storage	*12417	12573	12849	12762	12540	12394	12374	12358	12197	12083	11990
Elev NGVD29	*2221.9	2222.8	2224.2	2223.8	2222.6	2221.8	2221.7	2221.6	2220.7	2220.1	2219.6
Disch kcfs	*5.0	6.9	8.0	8.0	8.0	6.0	4.0	4.0	7.0	7.0	7.0
Ave Power MW		79	93	93	92	69	46	46	80	80	79
Ave Cap MW		204	206	206	205	204	203	203	203	202	201
Energy GWh	555.1	58.9	66.7	69.1	68.8	49.8	34.4	33.3	59.5	59.3	55.3
<b>Garrison</b>											
Reach Inflow	6202	966	1885	1235	427	322	408	296	200	200	263
Depletion	90	165	288	31	-45	-56	-122	-96	-41	-24	-10
Reg Inflow	10081	1197	2073	1696	964	769	776	630	647	654	676
Evap	468	-2	-29	13	91	117	113	99	67	-2	0
Release	10566	1079	1131	1168	1168	982	861	833	1083	1168	1093
Stor Change	-953	120	971	515	-296	-330	-198	-303	-503	-512	-418
Storage	*15333	15453	16424	16940	16644	16314	16116	15813	15310	14798	14380
Elev NGVD29	*1829.2	1829.7	1833.1	1834.8	1833.8	1832.7	1832.0	1830.9	1829.1	1827.3	1825.7
Disch kcfs	*16.6	17.5	19.0	19.0	19.0	16.5	14.0	14.0	17.6	19.0	19.0
Ave Power MW		210	229	232	233	202	171	170	211	225	222
Ave Cap MW		531	540	551	553	548	544	540	534	526	518
Energy GWh	1540.7	155.9	164.9	173.0	173.3	145.2	127.1	122.4	157.0	167.2	154.7
<b>Oahe</b>											
Reach Inflow	847	175	225	110	55	83	56	49	9	10	75
Depletion	109	25	38	50	20	0	-10	-7	-6	-4	2
Reg Inflow	11296	1221	1318	1228	1204	1082	927	889	1080	1182	1166
Evap	414	-14	-26	13	72	105	96	86	71	7	4
Release	12106	1098	1544	1795	1773	1509	951	691	809	1009	926
Stor Change	-1224	138	-200	-580	-641	-533	-120	112	200	166	235
Storage	*16411	16549	16349	15768	15127	14594	14474	14586	14786	14952	15187
Elev NGVD29	*1599.8	1600.3	1599.6	1597.4	1595.0	1592.9	1592.4	1592.9	1593.7	1594.3	1595.2
Disch kcfs	*9.1	17.9	25.9	29.2	28.8	25.4	15.5	11.6	13.2	16.4	16.1
Ave Power MW		204	293	325	315	274	167	125	143	179	177
Ave Cap MW		672	671	663	652	641	634	633	636	640	645
Energy GWh	1613.1	151.5	211.0	241.8	234.7	197.1	124.2	90.3	106.4	133.0	123.0
<b>Big Bend</b>											
Reg Inflow	12100	1091	1543	1794	1773	1512	955	692	810	1006	925
Evap	102	3	3	19	24	21	15	10	5	1	0
Release	12019	1102	1551	1751	1770	1480	935	703	770	1024	932
Storage	*1683	1669	1658	1681	1660	1671	1675	1653	1690	1671	1663
Elev NGVD29	*1420.9	1420.6	1420.4	1420.9	1420.5	1420.7	1420.7	1420.4	1421.0	1420.7	1420.5
Disch kcfs	*10.3	17.9	26.1	28.5	28.8	24.9	15.2	11.8	12.5	16.7	16.2
Ave Power MW		73	104	113	114	99	62	49	52	68	66
Ave Cap MW		447	435	432	432	436	451	456	456	448	449
Energy GWh	585.8	54.2	74.8	83.8	84.7	71.5	46.4	35.2	38.4	50.7	46.2
<b>Fort Randall</b>											
Reach Inflow	405	115	105	38	32	30	1	0	11	26	45
Depletion	117	6	24	50	32	12	-2	-2	-2	-1	-1
Reg Inflow	12289	1189	1629	1742	1768	1508	939	710	791	1038	975
Evap	122	-2	-1	13	27	34	30	14	6	1	1
Release	12582	1200	1613	1763	1726	1609	1611	1085	706	692	579
Stor Change	-416	-9	18	-34	14	-134	-701	-389	80	345	395
Storage	*3430	3421	3439	3404	3418	3285	2583	2195	2274	2619	3014
Elev NGVD29	*1355.2	1355.1	1355.4	1355.0	1355.1	1353.5	1344.1	1337.6	1339.0	1344.7	1350.2
Disch kcfs	*13.1	19.5	27.1	28.7	28.1	27.0	26.2	18.2	11.5	11.2	10.1
Ave Power MW		179	247	260	255	245	227	147	92	94	88
Ave Cap MW		381	381	381	381	379	361	325	317	335	355
Energy GWh	1345.3	133.4	177.6	193.7	189.8	176.1	169.1	106.0	68.5	69.7	61.4
<b>Gavins Point</b>											
Reach Inflow	869	98	95	77	78	86	90	90	75	75	105
Depletion	160	5	27	66	37	3	3	9	11	1	-1
Reg Inflow	13306	1259	1669	1775	1769	1696	1702	1215	767	768	685
Evap	32	2	1	6	5	6	6	4	2	0	0
Release	13276	1259	1667	1771	1752	1666	1697	1208	768	769	719
Stor Change	-2	-2	1	-1	11	24	-1	3	-2	-1	-34
Storage	*330	328	328	327	338	362	361	364	362	362	328
Elev NGVD29	*1206.1	1206.0	1206.0	1206.0	1206.5	1207.5	1207.5	1207.6	1207.5	1207.5	1206.0
Disch kcfs	*16.5	20.5	28.0	28.8	28.5	28.0	27.6	20.3	12.5	12.5	12.5
Ave Power MW		78	105	108	107	106	106	78	49	49	49
Ave Cap MW		125	125	125	125	127	127	127	127	127	126
Energy GWh	612.2	58.3	75.7	80.2	79.5	76.7	78.6	56.4	36.4	36.5	34.1
<b>Sioux City</b>											
Reach Inflow	1185	225	220	181	123	105	82	68	52	45	83
Depletion	273	17	52	128	79	10	-6	-4	-2	-1	-1
Reg Flow	14198	1449	1829	1824	1798	1762	1786	1321	814	815	802
Reg Flow kcfs		23.6	30.7	29.7	29.2	29.6	29.0	22.2	13.2	13.2	13.9
<b>Total</b>											
Reach Inflow	13659	2320	3570	2168	961	859	926	799	612	604	840
Depletion	950	379	716	404	23	-97	-139	-89	-90	-104	-53
Evap	1529	-11	-51	106	296	370	325	276	194	14	10
Storage											
Ave Power MW		823	1070	1131	1117	995	779	616	627	694	682
Ave Cap MW		2361	2358	2360	2348	2334	2320	2285	2273	2278	2293
Energy GWh	6252.2	612.2	770.6	841.5	830.7	716.3	579.9	443.5	466.4	516.4	474.6
Daily GWh		19.7	25.7	27.1	26.8	23.9	18.7	14.8	15.0	16.7	16.4

Date of Study: 02May2023

01May2023 / Upper Basic Condition / 34.0 MAF / Balanced  
Values in 1000 acre-ft Except as Indicated  
F-Sum: Sum of Forecasted Values. \*: Previous Month's Data

	2023									2024	
	*30Apr	31May	30Jun	31Jul	31Aug	30Sep	31Oct	30Nov	31Dec	31Jan	29Feb
	F-Sum										
<b>Fort Peck</b>											
Reach Inflow	7829	1431	2320	1174	455	372	432	444	396	372	432
Depletion	117	258	412	27	-169	-107	-29	-12	-87	-104	-72
Reg Inflow	7712	1173	1908	1148	624	479	461	456	483	476	504
Evap	449	3	1	47	86	100	75	74	52	7	4
Release	4919	496	595	615	615	431	277	268	492	584	546
Stor Change	2344	674	1312	486	-77	-53	109	115	-60	-115	-47
Storage	*12417	13091	14403	14889	14813	14760	14869	14984	14923	14808	14761
Elev NGVD29	*2221.9	2225.5	2232.2	2234.5	2234.1	2233.9	2234.4	2234.9	2234.6	2234.1	2233.9
Disch kcfs	*5.0	8.1	10.0	10.0	10.0	7.2	4.5	4.5	8.0	9.5	9.5
Ave Power MW		94	119	122	122	89	55	56	98	116	116
Ave Cap MW		206	212	218	219	218	219	219	219	219	218
Energy GWh	722.0	69.7	85.6	90.5	90.9	63.8	41.2	40.0	73.0	86.4	80.7
<b>Garrison</b>											
Reach Inflow	12208	1863	4205	2755	793	516	612	444	300	300	420
Depletion	351	72	801	293	-58	-106	-180	-161	-124	-109	-78
Reg Inflow	16737	2243	3999	3077	1466	1099	1068	872	887	981	1044
Evap	541	-2	-31	15	105	134	130	114	77	-2	0
Release	13809	1323	1607	1660	1660	1383	1138	1101	1140	1445	1352
Stor Change	2388	923	2423	1402	-299	-419	-200	-343	-330	-462	-308
Storage	*15333	16256	18679	20081	19782	19363	19164	18821	18491	18028	17721
Elev NGVD29	*1829.2	1832.5	1840.5	1844.7	1843.8	1842.6	1842.0	1840.9	1839.9	1838.4	1837.4
Disch kcfs	*16.6	21.5	27.0	27.0	27.0	23.2	18.5	18.5	18.5	23.5	23.5
Ave Power MW		257	331	342	344	296	236	235	234	293	292
Ave Cap MW		538	562	583	587	584	582	580	577	573	569
Energy GWh	2093.2	191.4	238.3	254.1	256.2	213.1	175.5	169.2	174.3	218.3	202.9
<b>Oahe</b>											
Reach Inflow	2102	543	652	280	115	148	101	88	16	18	140
Depletion	109	25	38	50	20	0	-10	-7	-6	-4	2
Reg Inflow	15778	1804	2222	1890	1755	1562	1249	1195	1147	1466	1490
Evap	503	-15	-28	15	85	127	117	104	84	9	5
Release	13052	630	1039	1796	1951	1688	1185	1340	1119	1228	1077
Stor Change	2223	1189	1211	79	-281	-254	-53	-248	-56	229	407
Storage	*16411	17600	18811	18889	18609	18355	18302	18054	17997	18227	18634
Elev NGVD29	*1599.8	1604.0	1608.0	1608.2	1607.3	1606.5	1606.3	1605.5	1605.3	1606.1	1607.4
Disch kcfs	*9.1	10.2	17.5	29.2	31.7	28.4	19.3	22.5	18.2	20.0	18.7
Ave Power MW		120	208	349	377	336	230	266	215	237	224
Ave Cap MW		680	702	712	710	707	703	701	697	700	705
Energy GWh	1874.8	89.0	149.7	259.3	280.3	242.3	170.8	191.7	160.1	176.0	155.7
<b>Big Bend</b>											
Reg Inflow	13046	625	1038	1791	1951	1690	1188	1339	1122	1226	1076
Evap	102	3	3	19	24	21	15	10	5	1	0
Release	12964	637	1047	1748	1947	1658	1168	1341	1090	1244	1084
Storage	*1683	1668	1656	1680	1660	1670	1675	1662	1690	1671	1663
Elev NGVD29	*1420.9	1420.6	1420.4	1420.8	1420.5	1420.7	1420.7	1420.5	1421.0	1420.7	1420.5
Disch kcfs	*10.3	10.4	17.6	28.4	31.7	27.9	19.0	22.5	17.7	20.2	18.8
Ave Power MW		43	72	112	124	110	77	90	72	82	77
Ave Cap MW		459	447	432	428	433	445	440	446	443	445
Energy GWh	629.7	31.9	51.6	83.6	92.5	79.5	57.4	65.1	53.7	61.0	53.3
<b>Fort Randall</b>											
Reach Inflow	1036	357	304	98	67	54	2	0	20	49	84
Depletion	117	6	24	50	32	12	-2	-2	-2	-1	-1
Reg Inflow	13863	971	1325	1791	1978	1711	1171	1341	1127	1281	1166
Evap	123	-2	-1	13	27	34	30	15	5	1	1
Release	14156	984	1292	1829	1930	1813	1812	1703	1090	932	770
Stor Change	-416	-11	34	-51	21	-135	-671	-376	31	348	395
Storage	*3430	3418	3452	3401	3422	3287	2616	2240	2271	2619	3014
Elev NGVD29	*1355.2	1355.1	1355.5	1354.9	1355.2	1353.6	1344.6	1338.4	1339.0	1344.7	1350.2
Disch kcfs	*13.1	16.0	21.7	29.7	31.4	30.5	29.5	28.6	17.7	15.2	13.4
Ave Power MW		148	199	270	284	275	255	231	140	125	117
Ave Cap MW		381	381	381	381	379	362	334	317	335	355
Energy GWh	1497.4	109.9	143.4	200.7	211.4	197.7	189.8	166.0	104.1	93.2	81.2
<b>Gavins Point</b>											
Reach Inflow	1886	302	275	196	162	155	162	162	135	140	196
Depletion	160	5	27	66	37	3	3	9	11	1	-1
Reg Inflow	15891	1259	1527	1942	2056	1969	1974	1855	1261	1075	974
Evap	32	2	1	6	5	6	6	4	2	0	0
Release	15861	1259	1523	1937	2041	1940	1968	1851	1259	1076	1007
Stor Change	-2	-2	2	-1	9	23	1	1	-0	-1	-33
Storage	*330	328	330	329	338	361	362	362	362	361	328
Elev NGVD29	*1206.1	1206.0	1206.1	1206.1	1206.5	1207.5	1207.5	1207.5	1207.5	1207.4	1206.0
Disch kcfs	*16.5	20.5	25.6	31.5	33.2	32.6	32.0	31.1	20.5	17.5	17.5
Ave Power MW		78	97	116	122	122	121	118	79	68	68
Ave Cap MW		125	125	125	125	127	127	127	127	127	126
Energy GWh	725.8	58.3	69.6	86.6	90.7	88.1	90.2	85.0	59.0	50.9	47.3
<b>Sioux City</b>											
Reach Inflow	2846	698	638	462	256	189	148	122	95	84	154
Depletion	273	17	52	128	79	10	-6	-4	-2	-1	-1
Reg Flow	18433	1921	2109	2258	2215	2120	2123	1978	1386	1161	1161
Reg Flow kcfs		31.2	35.4	36.7	36.0	35.6	34.5	33.2	22.5	18.9	20.2
<b>Total</b>											
Reach Inflow	27906	5193	8395	4965	1849	1435	1458	1260	962	963	1426
Depletion	1126	384	1353	613	-60	-187	-223	-177	-210	-218	-149
Evap	1749	-12	-55	115	334	423	373	320	225	16	11
Storage											
Ave Power MW		739	1025	1310	1374	1228	974	996	839	922	892
Ave Cap MW		2390	2430	2452	2451	2448	2438	2401	2384	2396	2418
Energy GWh	7542.9	550.2	738.3	974.8	1022.0	884.4	724.9	717.0	624.3	685.8	621.2
Daily GWh		17.7	24.6	31.4	33.0	29.5	23.4	23.9	20.1	22.1	21.4