

The regulation forecast is subject to change daily as actual events occur.  
 Forecasted release reductions or increases are subject to change based on forecasted temperature and river conditions  
 and releases may be adjusted during winter freeze-in period. Intrasystem regulation may also require release adjustments.

REGULATION FORECAST: 05/24/23

		FTPK				GARR				OAHE				BEND				FTRA				GAPT				SYSTEM				
		24EL	24ID	24OD	24GE	24EL	24ID	24OD	24GE	24EL	24ID	24OD	24GE	24EL	24ID	24OD	24GE	24EL	24ID	24OD	24GE	24EL	24ID	24OD	24GE	GE	SG	DSG		
W	24	2224.6	20.0	7.0	2.10	1831.2	41.7	22.0	6.38	1601.6	24.1	19.5	5.74	1420.6	19.9	22.5	2.36	1356.6	24.8	16.0	3.50	1207.2	19.4	20.0	1.88	21.97	51293	92	24	W
T	25	2224.7	18.9	7.0	2.10	1831.4	43.4	22.0	6.38	1601.6	24.0	19.5	5.74	1420.5	19.7	22.5	2.36	1356.8	24.5	16.0	3.50	1207.2	19.3	20.0	1.88	21.98	51377	84	25	T
F	26	2224.8	18.0	7.0	2.11	1831.5	44.9	22.0	6.39	1601.7	23.9	19.5	5.74	1420.4	19.6	22.5	2.35	1357.0	24.2	16.0	3.51	1207.1	19.0	20.0	1.88	21.98	51462	85	26	F
	27	2224.9	17.8	7.0	2.11	1831.7	45.9	22.0	6.40	1601.7	23.8	17.5	5.17	1420.7	18.0	9.0	0.98	1356.9	14.7	16.0	3.51	1207.0	18.9	20.0	1.88	20.04	51557	95	27	
	28	2225.0	17.7	7.0	2.11	1831.9	46.2	22.0	6.40	1601.8	23.8	15.5	4.59	1421.0	15.9	6.5	0.72	1356.8	10.2	16.0	3.51	1206.9	18.8	20.0	1.88	19.20	51648	91	28	
M	29	2225.2	17.7	7.0	2.11	1832.1	46.5	22.0	6.41	1601.8	24.2	19.5	5.75	1420.9	18.7	22.5	2.38	1356.9	19.5	16.0	3.51	1206.8	18.8	20.0	1.88	22.03	51726	78	29	M
T	30	2225.3	17.8	7.0	2.11	1832.2	45.3	22.0	6.41	1601.8	24.5	19.5	5.75	1420.8	19.5	22.5	2.37	1357.0	22.5	16.0	3.51	1206.7	18.7	20.0	1.87	22.03	51808	82	30	T
W	31	2225.4	17.8	7.0	2.11	1832.4	44.1	22.0	6.42	1601.9	24.9	19.5	5.75	1420.7	19.5	22.5	2.37	1357.2	24.0	16.0	3.51	1206.6	18.7	20.0	1.86	22.03	51891	83	31	W
T	1	2225.5	17.9	7.0	2.11	1832.5	42.8	22.0	6.43	1601.9	25.2	19.5	5.75	1420.6	19.5	22.5	2.36	1357.4	24.0	16.0	3.52	1206.4	18.6	20.0	1.85	22.02	51974	83	1	T
F	2	2225.6	18.0	7.0	2.11	1832.6	41.5	22.0	6.43	1602.0	25.8	19.5	5.75	1420.4	19.5	22.5	2.36	1357.6	24.0	15.5	3.42	1206.3	18.5	20.0	1.85	21.92	52058	84	2	F
	3	2225.7	18.1	9.0	2.71	1832.8	40.4	22.0	6.44	1602.0	26.4	17.5	5.18	1420.7	17.9	10.0	1.08	1357.5	15.3	17.0	3.74	1206.1	18.2	20.0	1.85	20.99	52139	81	3	
	4	2225.8	18.3	9.0	2.72	1832.9	39.3	22.0	6.44	1602.1	27.0	15.5	4.60	1421.0	15.9	7.5	0.82	1357.4	11.0	17.5	3.85	1206.0	18.8	20.0	1.84	20.27	52218	79	4	
M	5	2225.9	18.7	9.0	2.72	1833.0	39.1	22.0	6.45	1602.2	27.5	17.0	5.04	1420.9	16.7	20.0	2.13	1357.4	18.0	17.5	3.84	1206.0	19.4	20.0	1.84	22.01	52288	70	5	M
T	6	2226.0	19.0	9.0	2.72	1833.1	39.2	22.0	6.45	1602.3	27.8	17.0	5.04	1420.8	17.0	20.0	2.12	1357.5	20.3	18.0	3.95	1206.0	19.9	20.0	1.84	22.12	52363	75	6	T
W	7	2226.1	19.2	9.0	2.72	1833.3	39.4	22.0	6.46	1602.3	28.0	17.0	5.04	1420.7	17.0	20.0	2.12	1357.5	21.5	18.0	3.95	1206.0	20.2	20.0	1.84	22.13	52442	79	7	W
T	8	2226.2	19.2	9.0	2.72	1833.4	39.7	22.0	6.46	1602.4	28.0	17.0	5.04	1420.6	17.0	20.0	2.11	1357.6	21.5	18.0	3.96	1206.0	20.4	20.5	1.88	22.18	52522	80	8	T
F	9	2226.3	19.2	9.0	2.72	1833.5	39.9	22.0	6.46	1602.5	28.0	17.0	5.05	1420.5	17.0	20.0	2.11	1357.7	21.5	18.0	3.96	1206.0	20.5	20.5	1.88	22.19	52603	81	9	F
	10	2226.4	19.2	9.0	2.72	1833.6	40.0	22.0	6.47	1602.6	28.0	15.0	4.47	1420.7	15.4	7.5	0.82	1357.6	12.8	18.5	4.06	1206.0	20.5	20.5	1.88	20.43	52691	88	10	
	11	2226.5	19.2	9.0	2.73	1833.8	40.0	22.0	6.47	1602.7	28.0	13.0	3.88	1421.0	13.4	6.0	0.66	1357.4	9.2	18.5	4.06	1206.0	20.7	20.5	1.88	19.69	52775	84	11	
M	12	2226.6	19.2	9.0	2.73	1833.9	40.0	22.0	6.47	1602.8	27.9	16.0	4.76	1420.9	15.4	19.0	2.02	1357.3	16.8	18.5	4.06	1206.0	20.9	21.0	1.93	21.97	52845	70	12	M
T	13	2226.7	19.2	9.0	2.73	1834.0	40.0	22.0	6.47	1602.9	27.9	16.0	4.77	1420.8	16.0	19.0	2.02	1357.3	19.2	19.0	4.16	1206.0	21.0	21.0	1.93	22.08	52922	77	13	T
W	14	2226.8	19.3	9.0	2.73	1834.1	40.0	22.0	6.48	1603.0	27.9	16.0	4.77	1420.7	16.0	19.0	2.02	1357.4	20.5	19.0	4.16	1206.0	21.2	21.0	1.93	22.09	53001	79	14	W
T	15	2227.0	19.3	9.0	2.73	1834.3	40.0	22.0	6.48	1603.0	27.9	16.0	4.77	1420.6	16.0	19.0	2.01	1357.4	20.5	19.0	4.16	1206.0	21.4	21.5	1.97	22.14	53079	78	15	T
F	16	2227.1	19.3	9.0	2.73	1834.4	40.0	22.0	6.48	1603.1	27.9	16.0	4.78	1420.4	16.0	19.0	2.01	1357.4	20.5	19.5	4.27	1206.0	21.5	21.5	1.97	22.25	53156	77	16	F

**Project:**  
 24EL Midnight Elevation (NGVD29)  
 24ID Daily Average Inflow (kcfs)  
 24OD Daily Average Release (kcfs)  
 24GE Daily Power Generation (1000 MWh)

**System:**  
 GE Daily Power Generation (1000 MWh)  
 SG Midnight Storage (kaf)  
 DSG Daily Storage Change (kaf)

**Units:**  
 kcfs thousand cubic feet per second  
 MWh megawatt hour  
 kaf thousand acre-feet

The midnight elevation (24EL) will be shown in color when a reservoir enters one of the following zones.

- 1234.5 Exclusive Flood Control Zone (24EL)
- 1234.5 Surcharge Zone (24EL)

The daily average release (24OD) will be shown in color when a project's releases exceed the available power plant capacity.

34.5